



检测报告



二维码查询真伪

产品名称:	聚苯颗粒建筑隔墙保温条板
产品规格:	2440*610*200mm
检验类别:	委托检验
检测机构:	广东汇准检测科技有限公司
委托单位:	贵州西奥轻质节能板材有限公司


广东汇准检测科技有限公司

检验检测专用章

电话: 400-186-8638

网址: <http://www.zti-testing.com.cn/>

报 告 编 号：ZTi230830RS881

样品名称	聚苯颗粒建筑隔墙保温条板		样品型号	2440*610*200mm	
申请商	贵州西奥轻质节能板材有限公司				
申请商地址	贵州省长顺县鼠场工业园区				
商标	/				
生产商	贵州西奥轻质节能板材有限公司				
生产商地址	贵州省长顺县鼠场工业园区				
检验类别	委托检测		送样日期	2023年08月1日	
检测日期	2023年08月1日 --2023年08月30日				
测试依据	GB/T23450-2009《建筑隔墙用保温条板》 GB6566-2010《建筑材料放射性核素限量》 GB50574-2010《墙体材料应用统一技术规范》 GB/T19889.3-2005《声学 建筑和建筑构件隔声测量 第3部分 建筑构件空气隔声的实验室测量》 GB/T13475-2008《绝热 稳态传热性质的测定标定和防护热箱法》 GB/T9978.1-2008《建筑构件耐火试验方法 第1部分：通用要求》 GB8624-2012《建筑材料及制品燃烧性能分级》				
样品材质	/				
测试结果	该样品经检验，所检项目符合标准要求，结果合格				
环境温度	25.0℃		环境湿度	50.0%	
主检	吴琪	审核人	钟仁琳		
批准人	梁宇星	签发日期	2023 年 08 月 30 日		

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of ZTi Testing, this test report shall not be copied except in full and published as advertisement Guangdong ZTi Testing Co., Ltd.

广东汇准检测科技有限公司

Guangdong ZTi Testing Co., Ltd.

地址：广东省东莞市常平镇京九路5号101室

ADDRESS: Room 101, No. 5, Jingjiu Road, Changping Town, Dongguan City, Guangdong Province

网址：http://www.zti-testing.com.cn/

电话/TEL：400-186-8638

传真/Fax: 0769-86992213

报告编号：ZTi230830RS881

序号	检测项目		单位	技术要求	检测结果	单项判定
1	尺寸允许偏差	长度L	mm	±3	-3~-2	符合
		宽度B		±1	-1~0	
		厚度H		±0.5	-0.3~0	
	板面平整度			≤3	0~1	
	对角线差			≤L/600	2~4	
	侧向弯曲			≤L/1000	0.5~0.7	
2	容重		kg/m³	650-800	760	符合
3	抗压强度		MPa	≥4.3	5.2	符合
4	抗冲击性能		标准砂袋/次	≥5.0	经5次抗冲击试验后,板面无裂纹。	符合
5	软化系数		/	≥0.8	0.87	符合
6	含水率		%	≤10	6	符合
7	干缩率		mm/m	≤0.6	0.5	符合
8	吊挂力		N	≥1000	荷载1000N静置24小时,板面无裂纹。	符合
9	导热系数		W/(m.k)	≤0.2	0.14	符合

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of ZTi Testing, this test report shall not be copied except in full and published as advertisement Guangdong ZTi Testing Co., Ltd.

广东汇准检测科技有限公司

Guangdong ZTi Testing Co., Ltd.

地址：广东省东莞市常平镇京九路5号101室

ADDRESS: Room 101, No. 5, Jingjiu Road, Changping Town, Dongguan City, Guangdong Province

网址：<http://www.zti-testing.com.cn/>

电话/TEL：400-186-8638

传真/Fax：0769-86992213

报告编号：ZTi230830RS881

10	抗弯破坏荷载		板自重倍数	≥ 4	4.5	符合
11	耐火极限		h	≥ 4	4	符合
12	环保性		/	100%不含石棉, 不含甲醛、苯等对人体有害物质	100%不含石棉, 不含甲醛、苯等对人体有害物质	符合
13	放射性		内照射指数 IRt	≤ 1.0	0.4	符合
			外照射指数 1r	≤ 1.0	0.5	
14	燃烧性能 (A 级)	炉内温升 ΔT	$^{\circ}\text{C}$	≤ 30	11.5	符合
		持续燃烧时间 tf	s	0	0	
		质量损失率 Δm	%	≤ 50	10.0	
		整体制品总热值 PCS	MJ/kg	≤ 2.0	0.1	
15	空气隔声量		dB	≥ 50	51	符合

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of ZTi Testing, this test report shall not be copied except in full and published as advertisement Guangdong ZTi Testing Co., Ltd.

广东汇准检测科技有限公司

Guangdong ZTi Testing Co., Ltd.

地址：广东省东莞市常平镇京九路5号101室

ADDRESS: Room 101, No. 5, Jingjiu Road, Changping Town, Dongguan City, Guangdong Province

网址: <http://www.zti-testing.com.cn/>

电话/TEL: 400-186-8638

传真/Fax: 0769-86992213

报 告 编 号：ZTi230830RS881

样品图片



This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of ZTi Testing, this test report shall not be copied except in full and published as advertisement Guangdong ZTi Testing Co., Ltd.

广东汇准检测科技有限公司

Guangdong ZTi Testing Co., Ltd.

地址：广东省东莞市常平镇京九路 5 号 101 室

ADDRESS: Room 101, No. 5, Jingjiu Road, Changping Town, Dongguan City, Guangdong Province

网址：<http://www.zti-testing.com.cn/>

电话/TEL：400-186-8638

传真/Fax: 0769-86992213

报 告 编 号：ZTi230830RS881

注 意 事 项：

1. 报告无“检验检测报告章”或检验单位公章无效。
2. 未经本实验室书面同意，不得部分复制本报告。
3. 报告无主检、审核、批准人签字无效。
4. 报告涂改无效。
5. 对检测报告若有异议，应于收到报告之日起十五日内向检测单位提出，逾期不予受理。
6. 委托检测仪对来样负责。

地址：广东省东莞市常平镇京九路 5 号 101 室

Add: Room 101, No. 5, Jingjiu Road, Changping Town, Dongguan City, Guangdong Province

网址：<http://www.zti-testing.com.cn/>

***报告结束**

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of ZTi Testing, this test report shall not be copied except in full and published as advertisement Guangdong ZTi Testing Co., Ltd.

广东汇准检测科技有限公司

Guangdong ZTi Testing Co., Ltd.

地址：广东省东莞市常平镇京九路 5 号 101 室

ADDRESS: Room 101, No. 5, Jingjiu Road, Changping Town, Dongguan City, Guangdong Province

网址：<http://www.zti-testing.com.cn/>

电话/TEL：400-186-8638

传真/Fax：0769-86992213